



TO: ALL PLANHOLDERS OF RECORD
RE: 24T-DV-115 Salamatof Boiler Room Renovation
FROM: **Linda Vo**
PAGE(S): 2, including this cover sheet
DATE: **October 4, 2024**

Transmitted herewith is an Addendum to the solicitation listed above. If the Addendum is **not** received in full, please contact the Procurement Office at (907) 793-3000. If all pages of the Addendum are received, please sign this sheet, and email it back to CIHA's Procurement Department at Procurement@cookinlethousing.org.

Company's Name

Company's Representative

Date

Invitation to Bid 24T-DV-115, Addendum No. 5

This document forms a part of and modifies the solicitation as noted below. Respondents must acknowledge receipt of this addendum. Failure to acknowledge receipt of this addendum may subject Respondent to disqualification.

PROJECT: Salamatof Boiler Room Renovation
FOR: Cook Inlet Housing Authority

The following corrections, clarifications, additions, and/or deletions to the ITB 24T-DV-115 are hereby made a part of said documents. All other terms and conditions remain the same.

This Addendum Shall:

1. Respond to all questions submitted.

Questions	Answers
1. Will the HVAC equipment being replaced require Direct Digital Control? On recent CIHA projects, this has been a requirement, but there's no specifics regarding Direct Digital Controls on this project.	No. Direct Digital Controls are not part of this project.

END OF ADDENDUM